

25X1A9a

7 1953

25X1A9a

WEATHER STRIPPING SPECIFIED. PARAGRAPH 18.31 REFERS TO SIMPLE SPRING STRIPPING FASTENED TO BOTTOM OF DOOR. DETAIL WILL FOLLOW BY MAIL. THIS WEATHER STRIPPING SHOULD APPLY TO ALL EXTERIOR DOORS THAT SWING OUT AND HAVE METAL THRESHOLDS. AS THE TRANSFORMER VAULT DOORS HAVE NO THRESHOLDS INDICATED, THEY WILL NOT REQUIRE THE WEATHERSTRIPPING. HOWEVER, THE PENTHOUSE DOORS THAT YOU REFER TO WILL REQUIRE WEATHERSTRIPPING.

RE ADDENDUM NO. 1, PAGE 1, PARAGRAPH DRAWING NO. 9-5. CRANE COMPANY VALVE NO. 58 APPEARS TO BE THE ONLY TYPE VALVE THAT WILL OPERATE IN BOX BELOW GRADE. SINCE THE STREETWASHER ARRANGEMENT THAT WAS ORIGINALLY SPECIFIED HAS BEEN DELETED USE ELBOW ON WATER LINE IN BOX AND KEEP VALVE BELOW FROST LINE.

27/2313Z